

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17

ANALYTICAL REPORT

PREPARED FOR

Attn: Mr. Erwin Kawata
City & County of Honolulu
630 South Beretania Street
Public Service Bldg. Room 310
Honolulu, Hawaii 96843

Generated 3/11/2026 5:14:44 PM

JOB DESCRIPTION

RED-HILL
PFAS: Moanalua Wells

JOB NUMBER

380-201236-1

Eurofins Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Drinking Water and Wastewater West, LLC Project Manager.

Compliance Statement

1. Laboratory is accredited in accordance with TNI 2016 Standards and ISO/IEC 17025:2017.
2. Laboratory certifies that the test results meet all TNI 2016 and ISO/IEC 17025:2017 requirements unless noted under the individual analysis
3. Test results relate only to the sample(s) tested.
4. This report shall not be reproduced except in full, without the written approval of the laboratory.
5. Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below. (DW, Water matrices)

Authorization



Authorized for release by
Maria Lopez, Project Manager
Maria.Lopez@et.eurofinsus.com
(626)386-1100

Generated
3/11/2026 5:14:44 PM



Table of Contents

Cover Page	1
Table of Contents	3
Definitions/Glossary	4
Case Narrative	5
Detection Summary	6
Client Sample Results	7
Action Limit Summary	11
Surrogate Summary	12
Isotope Dilution Summary	13
QC Sample Results	15
QC Association Summary	26
Lab Chronicle	27
Certification Summary	28
Method Summary	29
Sample Summary	30
Chain of Custody	31
Receipt Checklists	33

Definitions/Glossary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Qualifiers

LCMS

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: City & County of Honolulu
Project: RED-HILL

Job ID: 380-201236-1

Job ID: 380-201236-1

Eurofins Pomona

Job Narrative 380-201236-1

The analytical test results presented in this report meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page, unless otherwise noted. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable. Regulated compliance samples (e.g. SDWA, NPDES) must comply with associated agency requirements/permits.

- Matrix-specific batch QC (e.g., MS, MSD, SD) may not be reported when insufficient sample volume is available or when site-specific QC samples are not submitted. In such cases, a Laboratory Control Sample Duplicate (LCSD) may be analyzed to provide precision data for the batch.
- For samples analyzed using surrogate and/or isotope dilution analytes, any recoveries falling outside of established acceptance criteria are re-prepared and/or re-analyzed to confirm results, unless the deviation is due to sample dilution or otherwise explained in the case narrative.

Receipt

The samples were received on 3/4/2026 10:01 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 2.0°C.

PFAS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.



Detection Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-1

No Detections.

Client Sample ID: FB MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-2

No Detections.

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

This Detection Summary does not include radiochemical test results.

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-1

Date Collected: 03/02/26 10:16

Matrix: Drinking Water

Date Received: 03/04/26 10:01

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:31	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	87		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C6 PFDA	79		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C5 PFHxA	93		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C4 PFHpA	89		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C8 PFOA	92		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C9 PFNA	88		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C7 PFUnA	78		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C2 PFDoA	85		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C4 PFBA	100		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C5 PFPeA	96		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C3 PFBS	116		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C3 PFHxS	112		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C8 PFOS	107		50 - 200	03/07/26 05:29	03/08/26 17:31	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-1

Date Collected: 03/02/26 10:16

Matrix: Drinking Water

Date Received: 03/04/26 10:01

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C2-4:2-FTS	121		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C2-6:2-FTS	113		50 - 200	03/07/26 05:29	03/08/26 17:31	1
13C2-8:2-FTS	107		50 - 200	03/07/26 05:29	03/08/26 17:31	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:00	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	101		70 - 130			03/09/26 01:16	03/10/26 01:00	1
13C2 PFHxA	94		70 - 130			03/09/26 01:16	03/10/26 01:00	1
13C2 PFDA	106		70 - 130			03/09/26 01:16	03/10/26 01:00	1
13C3-GenX	94		70 - 130			03/09/26 01:16	03/10/26 01:00	1

Client Sample ID: FB MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-2

Date Collected: 03/02/26 10:16

Matrix: Water

Date Received: 03/04/26 10:01

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Client Sample ID: FB MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-2

Date Collected: 03/02/26 10:16

Matrix: Water

Date Received: 03/04/26 10:01

Method: EPA 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluorobutanoic acid (PFBA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluoropentanoic acid (PFPeA)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1
Perfluoropentanesulfonic acid (PFPeS)	<2.0		2.0	ng/L		03/07/26 05:29	03/08/26 17:41	1

Isotope Dilution	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	98		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C6 PFDA	113		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C5 PFHxA	105		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C4 PFHpA	109		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C8 PFOA	119		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C9 PFNA	115		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C7 PFUnA	114		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C2 PFDoA	116		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C4 PFBA	112		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C5 PFPeA	104		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C3 PFBS	111		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C3 PFHxS	115		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C8 PFOS	114		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C2-4:2-FTS	118		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C2-6:2-FTS	116		50 - 200	03/07/26 05:29	03/08/26 17:41	1
13C2-8:2-FTS	115		50 - 200	03/07/26 05:29	03/08/26 17:41	1

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorooctanesulfonic acid (PFOS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluoroundecanoic acid (PFUnA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1

Eurofins Pomona

Client Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Client Sample ID: FB MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-2

Date Collected: 03/02/26 10:16

Matrix: Water

Date Received: 03/04/26 10:01

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Analyte	Result	Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorohexanoic acid (PFHxA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorododecanoic acid (PFDoA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorooctanoic acid (PFOA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorodecanoic acid (PFDA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorohexanesulfonic acid (PFHxS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorobutanesulfonic acid (PFBS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluoroheptanoic acid (PFHpA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorononanoic acid (PFNA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorotetradecanoic acid (PFTA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Perfluorotridecanoic acid (PFTrDA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		2.0	ng/L		03/09/26 01:16	03/10/26 01:10	1
Surrogate	%Recovery	Qualifier	Limits			Prepared	Analyzed	Dil Fac
d5-NEtFOSAA	113		70 - 130			03/09/26 01:16	03/10/26 01:10	1
13C2 PFHxA	98		70 - 130			03/09/26 01:16	03/10/26 01:10	1
13C2 PFDA	115		70 - 130			03/09/26 01:16	03/10/26 01:10	1
13C3-GenX	93		70 - 130			03/09/26 01:16	03/10/26 01:10	1

Action Limit Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Client Sample ID: FB MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL	RL	Method	Prep Type
				Limit			
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	533	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	533	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	533	Total/NA
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanesulfonic acid (PFOS)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorooctanoic acid (PFOA)	<2.0		ng/L	4	2.0	EPA 537.1 V2	Total/NA
Perfluorohexanesulfonic acid (PFHxS)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA
Perfluorononanoic acid (PFNA)	<2.0		ng/L	10	2.0	EPA 537.1 V2	Total/NA

Surrogate Summary

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-201236-1
 SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Drinking Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-201236-1	MOANALUA WELLS (331-223-T	101	94	106	94

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
 PFHxA = 13C2 PFHxA
 PFDA = 13C2 PFDA
 GenX = 13C3-GenX

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		d5NEFOS (70-130)	PFHxA (70-130)	PFDA (70-130)	GenX (70-130)
380-200977-T-1-A MS	Matrix Spike	107	91	109	95
380-200977-U-1-A MSD	Matrix Spike Duplicate	103	97	106	96
380-201236-2	FB MOANALUA WELLS (331-223-TP202)	113	98	115	93
LCS 380-211717/21-A	Lab Control Sample	102	90	107	73
MBL 380-211717/19-A	Method Blank	87	87	107	76
MRL 380-211717/20-A	Lab Control Sample	85	93	105	73

Surrogate Legend

d5NEFOS = d5-NEtFOSAA
 PFHxA = 13C2 PFHxA
 PFDA = 13C2 PFDA
 GenX = 13C3-GenX

Isotope Dilution Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Drinking Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-201236-1	MOANALUA WELLS (331-223-T	87	79	93	89	92	88	78	85

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-201236-1	MOANALUA WELLS (331-223-T	100	96	116	112	107	121	113	107

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA
- C4PFHA = 13C4 PFHpA
- C8PFOA = 13C8 PFOA
- C9PFNA = 13C9 PFNA
- 13C7PUA = 13C7 PFUnA
- PFDaA = 13C2 PFDaA
- PFBA = 13C4 PFBA
- PFPeA = 13C5 PFPeA
- C3PFBS = 13C3 PFBS
- C3PFHS = 13C3 PFHxS
- C8PFOS = 13C8 PFOS
- 42FTS = 13C2-4:2-FTS
- 62FTS = 13C2-6:2-FTS
- 82FTS = 13C2-8:2-FTS

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Matrix: Water

Prep Type: Total/NA

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	HFPODA (50-200)	C6PFDA (50-200)	13C5PHA (50-200)	C4PFHA (50-200)	C8PFOA (50-200)	C9PFNA (50-200)	13C7PUA (50-200)	PFDaA (50-200)
380-201236-2	FB MOANALUA WELLS (331-223-T	98	113	105	109	119	115	114	116
380-201381-B-1-A MS	Matrix Spike	109	116	108	110	114	121	122	121
380-201381-C-1-A MSD	Matrix Spike Duplicate	106	116	107	109	117	115	119	123
LCS 380-211527/22-A	Lab Control Sample	95	117	110	111	112	116	121	122
MBL 380-211527/20-A	Method Blank	94	116	107	109	121	122	118	125
MRL 380-211527/21-A	Lab Control Sample	98	116	109	105	116	116	113	115

Percent Isotope Dilution Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	PFBA (50-200)	PFPeA (50-200)	C3PFBS (50-200)	C3PFHS (50-200)	C8PFOS (50-200)	42FTS (50-200)	62FTS (50-200)	82FTS (50-200)
380-201236-2	FB MOANALUA WELLS (331-223-T	112	104	111	115	114	118	116	115
380-201381-B-1-A MS	Matrix Spike	114	129	113	112	115	120	121	121
380-201381-C-1-A MSD	Matrix Spike Duplicate	114	132	110	117	116	134	135	124
LCS 380-211527/22-A	Lab Control Sample	111	107	111	115	113	106	109	112
MBL 380-211527/20-A	Method Blank	117	110	121	117	121	118	118	117
MRL 380-211527/21-A	Lab Control Sample	112	111	117	113	116	116	111	117

Surrogate Legend

- HFPODA = 13C3 HFPO-DA
- C6PFDA = 13C6 PFDA
- 13C5PHA = 13C5 PFHxA

Isotope Dilution Summary

Client: City & County of Honolulu

Project/Site: RED-HILL

C4PFHA = 13C4 PFHpA
C8PFOA = 13C8 PFOA
C9PFNA = 13C9 PFNA
13C7PUA = 13C7 PFUnA
PFDoA = 13C2 PFDoA
PFBA = 13C4 PFBA
PFPeA = 13C5 PFPeA
C3PFBS = 13C3 PFBS
C3PFHS = 13C3 PFHxS
C8PFOS = 13C8 PFOS
42FTS = 13C2-4:2-FTS
62FTS = 13C2-6:2-FTS
82FTS = 13C2-8:2-FTS

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water

Lab Sample ID: MBL 380-211527/20-A
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 211527

Analyte	MBL Result	MBL Qualifier	RL	Unit	D	Prepared	Analyzed	Dil Fac
11-Chloroeicosfluoro-3-oxaundecan e-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
9-Chlorohexadecafluoro-3-oxanonan e-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluorobutanoic acid (PFBA)	<0.69		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<0.38		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<0.37		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<0.48		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<0.47		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<0.25		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluoro-3-methoxypropanoic acid (PFMPA)	<0.46		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluoro-4-methoxybutanoic acid (PFMBA)	<0.15		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluoropentanoic acid (PFPeA)	<0.38		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluoroheptanesulfonic acid (PFHpS)	<0.36		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1
Perfluoropentanesulfonic acid (PFPeS)	<0.39		2.0	ng/L		03/07/26 05:29	03/08/26 14:22	1

Isotope Dilution	MBL %Recovery	MBL Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	94		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C6 PFDA	116		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C5 PFHxA	107		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C4 PFHpA	109		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C8 PFOA	121		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C9 PFNA	122		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C7 PFUnA	118		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C2 PFDoA	125		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C4 PFBA	117		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C5 PFPeA	110		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C3 PFBS	121		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C3 PFHxS	117		50 - 200	03/07/26 05:29	03/08/26 14:22	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MBL 380-211527/20-A
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 211527

<i>Isotope Dilution</i>	<i>MBL %Recovery</i>	<i>MBL Qualifier</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C8 PFOS	121		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C2-4:2-FTS	118		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C2-6:2-FTS	118		50 - 200	03/07/26 05:29	03/08/26 14:22	1
13C2-8:2-FTS	117		50 - 200	03/07/26 05:29	03/08/26 14:22	1

Lab Sample ID: LCS 380-211527/22-A
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 211527

<i>Analyte</i>	<i>Spike Added</i>	<i>LCS Result</i>	<i>LCS Qualifier</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec Limits</i>
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	60.0	51.6		ng/L		86	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	60.0	58.4		ng/L		97	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	60.0	56.2		ng/L		94	70 - 130
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	60.0	57.6		ng/L		96	70 - 130
Perfluorobutanesulfonic acid (PFBS)	60.0	60.2		ng/L		100	70 - 130
Perfluorodecanoic acid (PFDA)	60.0	58.6		ng/L		98	70 - 130
Perfluorododecanoic acid (PFDoA)	60.0	58.2		ng/L		97	70 - 130
Perfluoroheptanoic acid (PFHpA)	60.0	57.5		ng/L		96	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	60.0	56.2		ng/L		94	70 - 130
Perfluorohexanoic acid (PFHxA)	60.0	55.3		ng/L		92	70 - 130
Perfluorononanoic acid (PFNA)	60.0	56.3		ng/L		94	70 - 130
Perfluorooctanesulfonic acid (PFOS)	60.0	57.3		ng/L		95	70 - 130
Perfluorooctanoic acid (PFOA)	60.0	57.4		ng/L		96	70 - 130
Perfluoroundecanoic acid (PFUnA)	60.0	57.4		ng/L		96	70 - 130
Perfluorobutanoic acid (PFBA)	60.0	58.5		ng/L		98	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	60.0	62.3		ng/L		104	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	60.0	60.0		ng/L		100	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	60.0	60.1		ng/L		100	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	60.0	64.7		ng/L		108	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	60.0	60.3		ng/L		100	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	60.0	61.9		ng/L		103	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	60.0	57.1		ng/L		95	70 - 130
Perfluoropentanoic acid (PFPeA)	60.0	56.8		ng/L		95	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	60.0	57.5		ng/L		96	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: LCS 380-211527/22-A
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 211527

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Perfluoropentanesulfonic acid (PFPeS)	60.0	56.1		ng/L		94	70 - 130
LCS LCS							
Isotope Dilution	%Recovery	Qualifier	Limits				
13C3 HFPO-DA	95		50 - 200				
13C6 PFDA	117		50 - 200				
13C5 PFHxA	110		50 - 200				
13C4 PFHpA	111		50 - 200				
13C8 PFOA	112		50 - 200				
13C9 PFNA	116		50 - 200				
13C7 PFUnA	121		50 - 200				
13C2 PFDoA	122		50 - 200				
13C4 PFBA	111		50 - 200				
13C5 PFPeA	107		50 - 200				
13C3 PFBS	111		50 - 200				
13C3 PFHxS	115		50 - 200				
13C8 PFOS	113		50 - 200				
13C2-4:2-FTS	106		50 - 200				
13C2-6:2-FTS	109		50 - 200				
13C2-8:2-FTS	112		50 - 200				

Lab Sample ID: MRL 380-211527/21-A
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 211527

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.83	J	ng/L		91	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	1.99	J	ng/L		99	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	2.21	J	ng/L		110	50 - 150
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	2.06	J	ng/L		103	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	2.18	J	ng/L		109	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	2.09	J	ng/L		104	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.22	J	ng/L		111	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	2.20	J	ng/L		110	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	2.09	J	ng/L		104	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	2.20	J	ng/L		110	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.06	J	ng/L		103	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	2.13	J	ng/L		106	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	2.13	J	ng/L		106	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.07	J	ng/L		104	50 - 150
Perfluorobutanoic acid (PFBA)	2.00	2.19	J	ng/L		109	50 - 150

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: MRL 380-211527/21-A
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 211527

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	%Rec Limits
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	2.00	2.25	J	ng/L		112	50 - 150
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	2.00	2.36	J	ng/L		118	50 - 150
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	2.00	2.39	J	ng/L		119	50 - 150
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	2.00	1.99	J	ng/L		99	50 - 150
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	2.00	2.21	J	ng/L		110	50 - 150
Perfluoro-3-methoxypropanoic acid (PFMPA)	2.00	2.27	J	ng/L		113	50 - 150
Perfluoro-4-methoxybutanoic acid (PFMBA)	2.00	2.09	J	ng/L		104	50 - 150
Perfluoropentanoic acid (PFPeA)	2.00	2.15	J	ng/L		107	50 - 150
Perfluoroheptanesulfonic acid (PFHpS)	2.00	2.13	J	ng/L		106	50 - 150
Perfluoropentanesulfonic acid (PFPeS)	2.00	2.15	J	ng/L		107	50 - 150

Isotope Dilution	MRL %Recovery	MRL Qualifier	MRL Limits
13C3 HFPO-DA	98		50 - 200
13C6 PFDA	116		50 - 200
13C5 PFHxA	109		50 - 200
13C4 PFHpA	105		50 - 200
13C8 PFOA	116		50 - 200
13C9 PFNA	116		50 - 200
13C7 PFUnA	113		50 - 200
13C2 PFDoA	115		50 - 200
13C4 PFBA	112		50 - 200
13C5 PFPeA	111		50 - 200
13C3 PFBS	117		50 - 200
13C3 PFHxS	113		50 - 200
13C8 PFOS	116		50 - 200
13C2-4:2-FTS	116		50 - 200
13C2-6:2-FTS	111		50 - 200
13C2-8:2-FTS	117		50 - 200

Lab Sample ID: 380-201381-B-1-A MS
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 211527

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.1	52.9		ng/L		88	70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.1	58.6		ng/L		98	70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.1	56.8		ng/L		94	70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-201381-B-1-A MS
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 211527

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Hexafluoropropylene Oxide	<2.0		60.1	56.4		ng/L		94	70 - 130
Dimer Acid (HFPO-DA/GenX)									
Perfluorobutanesulfonic acid (PFBS)	2.4		60.1	60.8		ng/L		97	70 - 130
Perfluorodecanoic acid (PFDA)	<2.0		60.1	58.0		ng/L		97	70 - 130
Perfluorododecanoic acid (PFDoA)	<2.0		60.1	59.4		ng/L		99	70 - 130
Perfluoroheptanoic acid (PFHpA)	<2.0		60.1	61.2		ng/L		99	70 - 130
Perfluorohexanesulfonic acid (PFHxS)	<2.0		60.1	59.4		ng/L		96	70 - 130
Perfluorohexanoic acid (PFHxA)	3.2		60.1	59.2		ng/L		93	70 - 130
Perfluorononanoic acid (PFNA)	<2.0		60.1	55.7		ng/L		93	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		60.1	58.2		ng/L		94	70 - 130
Perfluorooctanoic acid (PFOA)	3.5		60.1	59.9		ng/L		94	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		60.1	56.8		ng/L		94	70 - 130
Perfluorobutanoic acid (PFBA)	2.0		60.1	58.6		ng/L		94	70 - 130
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.1	61.5		ng/L		102	70 - 130
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.1	60.4		ng/L		100	70 - 130
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.1	60.9		ng/L		101	70 - 130
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		60.1	61.7		ng/L		103	70 - 130
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.1	62.4		ng/L		104	70 - 130
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.1	70.4		ng/L		117	70 - 130
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.1	57.4		ng/L		95	70 - 130
Perfluoropentanoic acid (PFPeA)	2.2		60.1	57.1		ng/L		91	70 - 130
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.1	57.7		ng/L		96	70 - 130
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.1	57.5		ng/L		96	70 - 130

Isotope Dilution	MS MS		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	109		50 - 200
13C6 PFDA	116		50 - 200
13C5 PFHxA	108		50 - 200
13C4 PFHpA	110		50 - 200
13C8 PFOA	114		50 - 200
13C9 PFNA	121		50 - 200
13C7 PFUnA	122		50 - 200
13C2 PFDoA	121		50 - 200
13C4 PFBA	114		50 - 200
13C5 PFPeA	129		50 - 200
13C3 PFBS	113		50 - 200
13C3 PFHxS	112		50 - 200
13C8 PFOS	115		50 - 200

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Lab Sample ID: 380-201381-B-1-A MS
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 211527

<i>Isotope Dilution</i>	<i>%Recovery</i>	<i>MS MS Qualifier</i>	<i>Limits</i>
13C2-4:2-FTS	120		50 - 200
13C2-6:2-FTS	121		50 - 200
13C2-8:2-FTS	121		50 - 200

Lab Sample ID: 380-201381-C-1-A MSD
Matrix: Water
Analysis Batch: 211576

Client Sample ID: Matrix Spike Duplicate
Prep Type: Total/NA
Prep Batch: 211527

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<2.0		60.1	54.4		ng/L		90	70 - 130	3	30
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<2.0		60.1	58.7		ng/L		98	70 - 130	0	30
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0		60.1	60.2		ng/L		100	70 - 130	6	30
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		60.1	61.3		ng/L		102	70 - 130	8	30
Perfluorobutanesulfonic acid (PFBS)	2.4		60.1	65.1		ng/L		104	70 - 130	7	30
Perfluorodecanoic acid (PFDA)	<2.0		60.1	58.9		ng/L		98	70 - 130	1	30
Perfluorododecanoic acid (PFDoA)	<2.0		60.1	60.3		ng/L		100	70 - 130	1	30
Perfluoroheptanoic acid (PFHpA)	<2.0		60.1	61.9		ng/L		100	70 - 130	1	30
Perfluorohexanesulfonic acid (PFHxS)	<2.0		60.1	58.8		ng/L		95	70 - 130	1	30
Perfluorohexanoic acid (PFHxA)	3.2		60.1	60.9		ng/L		96	70 - 130	3	30
Perfluorononanoic acid (PFNA)	<2.0		60.1	58.6		ng/L		97	70 - 130	5	30
Perfluorooctanesulfonic acid (PFOS)	<2.0		60.1	58.9		ng/L		96	70 - 130	1	30
Perfluorooctanoic acid (PFOA)	3.5		60.1	60.7		ng/L		95	70 - 130	1	30
Perfluoroundecanoic acid (PFUnA)	<2.0		60.1	58.9		ng/L		98	70 - 130	4	30
Perfluorobutanoic acid (PFBA)	2.0		60.1	61.8		ng/L		99	70 - 130	5	30
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	<2.0		60.1	62.0		ng/L		103	70 - 130	1	30
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	<2.0		60.1	58.9		ng/L		98	70 - 130	3	30
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	<2.0		60.1	61.3		ng/L		102	70 - 130	1	30
Nonfluoro-3,6-dioxaheptanoic acid (NFDHA)	<2.0		60.1	63.0		ng/L		105	70 - 130	2	30
Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	<2.0		60.1	65.9		ng/L		110	70 - 130	5	30
Perfluoro-3-methoxypropanoic acid (PFMPA)	<2.0		60.1	69.8		ng/L		116	70 - 130	1	30
Perfluoro-4-methoxybutanoic acid (PFMBA)	<2.0		60.1	59.5		ng/L		99	70 - 130	4	30
Perfluoropentanoic acid (PFPeA)	2.2		60.1	59.3		ng/L		95	70 - 130	4	30
Perfluoroheptanesulfonic acid (PFHpS)	<2.0		60.1	59.5		ng/L		99	70 - 130	3	30
Perfluoropentanesulfonic acid (PFPeS)	<2.0		60.1	59.0		ng/L		98	70 - 130	2	30

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: 533 - Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water (Continued)

Isotope Dilution	MSD MSD		Limits
	%Recovery	Qualifier	
13C3 HFPO-DA	106		50 - 200
13C6 PFDA	116		50 - 200
13C5 PFHxA	107		50 - 200
13C4 PFHpA	109		50 - 200
13C8 PFOA	117		50 - 200
13C9 PFNA	115		50 - 200
13C7 PFUnA	119		50 - 200
13C2 PFDoA	123		50 - 200
13C4 PFBA	114		50 - 200
13C5 PFPeA	132		50 - 200
13C3 PFBS	110		50 - 200
13C3 PFHxS	117		50 - 200
13C8 PFOS	116		50 - 200
13C2-4:2-FTS	134		50 - 200
13C2-6:2-FTS	135		50 - 200
13C2-8:2-FTS	124		50 - 200

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020

Lab Sample ID: MBL 380-211717/19-A
Matrix: Water
Analysis Batch: 211878

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 211717

Analyte	MBL MBL		RL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier						
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<1.0		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorooctanesulfonic acid (PFOS)	<0.43		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluoroundecanoic acid (PFUnA)	<0.42		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.58		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.42		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorohexanoic acid (PFHxA)	<0.46		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorododecanoic acid (PFDoA)	<0.54		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorooctanoic acid (PFOA)	<0.38		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorodecanoic acid (PFDA)	<0.31		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorohexanesulfonic acid (PFHxS)	<0.32		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorobutanesulfonic acid (PFBS)	<0.37		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluoroheptanoic acid (PFHpA)	<0.39		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorononanoic acid (PFNA)	<0.40		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorotetradecanoic acid (PFTA)	<0.54		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Perfluorotridecanoic acid (PFTrDA)	<0.36		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	<0.30		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	<0.30		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.60		2.0	ng/L		03/09/26 01:16	03/09/26 22:56	1
Surrogate	MBL MBL		Limits			Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier						
d5-NEtFOSAA	87		70 - 130			03/09/26 01:16	03/09/26 22:56	1
13C2 PFHxA	87		70 - 130			03/09/26 01:16	03/09/26 22:56	1
13C2 PFDA	107		70 - 130			03/09/26 01:16	03/09/26 22:56	1

Eurofins Pomona

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MBL 380-211717/19-A
Matrix: Water
Analysis Batch: 211878

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 211717

<i>Surrogate</i>	<i>MBL</i>	<i>MBL</i>	<i>Limits</i>	<i>Prepared</i>	<i>Analyzed</i>	<i>Dil Fac</i>
13C3-GenX	76	Qualifier	70 - 130	03/09/26 01:16	03/09/26 22:56	1

Lab Sample ID: LCS 380-211717/21-A
Matrix: Water
Analysis Batch: 211878

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 211717

<i>Analyte</i>	<i>Spike</i>	<i>LCS</i>	<i>LCS</i>	<i>Unit</i>	<i>D</i>	<i>%Rec</i>	<i>%Rec</i>	<i>Limits</i>
	<i>Added</i>	<i>Result</i>	<i>Qualifier</i>					
Hexafluoropropylene Oxide	25.1	18.5		ng/L		74		70 - 130
Dimer Acid (HFPO-DA/GenX)								
Perfluorooctanesulfonic acid (PFOS)	25.1	24.1		ng/L		96		70 - 130
Perfluoroundecanoic acid (PFUnA)	25.1	24.3		ng/L		97		70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	25.1	23.1		ng/L		92		70 - 130
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	25.1	23.9		ng/L		95		70 - 130
Perfluorohexanoic acid (PFHxA)	25.1	21.5		ng/L		85		70 - 130
Perfluorododecanoic acid (PFDoA)	25.1	25.4		ng/L		101		70 - 130
Perfluorooctanoic acid (PFOA)	25.1	24.1		ng/L		96		70 - 130
Perfluorodecanoic acid (PFDA)	25.1	25.1		ng/L		100		70 - 130
Perfluorohexanesulfonic acid (PFHxS)	25.1	26.1		ng/L		104		70 - 130
Perfluorobutanesulfonic acid (PFBS)	25.1	24.8		ng/L		99		70 - 130
Perfluoroheptanoic acid (PFHpA)	25.1	23.8		ng/L		95		70 - 130
Perfluorononanoic acid (PFNA)	25.1	25.0		ng/L		99		70 - 130
Perfluorotetradecanoic acid (PFTA)	25.1	19.3		ng/L		77		70 - 130
Perfluorotridecanoic acid (PFTrDA)	25.1	24.5		ng/L		98		70 - 130
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9Cl-PF3ONS)	25.1	25.7		ng/L		102		70 - 130
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	25.1	23.8		ng/L		95		70 - 130
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	25.1	20.1		ng/L		80		70 - 130

<i>Surrogate</i>	<i>LCS</i>	<i>LCS</i>	<i>Limits</i>
	<i>%Recovery</i>	<i>Qualifier</i>	
d5-NEtFOSAA	102		70 - 130
13C2 PFHxA	90		70 - 130
13C2 PFDA	107		70 - 130
13C3-GenX	73		70 - 130

QC Sample Results

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method: EPA 537.1 V2 - EPA 537.1 Ver. 2.0 March 2020 (Continued)

Lab Sample ID: MRL 380-211717/20-A
Matrix: Water
Analysis Batch: 211878

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 211717

Analyte	Spike Added	MRL Result	MRL Qualifier	Unit	D	%Rec	Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	2.00	1.46	J	ng/L		73	50 - 150
Perfluorooctanesulfonic acid (PFOS)	2.00	2.06	J	ng/L		103	50 - 150
Perfluoroundecanoic acid (PFUnA)	2.00	2.08	J	ng/L		104	50 - 150
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	2.00	1.88	J	ng/L		94	50 - 150
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA)	2.00	1.92	J	ng/L		96	50 - 150
Perfluorohexanoic acid (PFHxA)	2.00	1.78	J	ng/L		89	50 - 150
Perfluorododecanoic acid (PFDoA)	2.00	2.06	J	ng/L		103	50 - 150
Perfluorooctanoic acid (PFOA)	2.00	1.95	J	ng/L		97	50 - 150
Perfluorodecanoic acid (PFDA)	2.00	1.98	J	ng/L		99	50 - 150
Perfluorohexanesulfonic acid (PFHxS)	2.00	2.04	J	ng/L		102	50 - 150
Perfluorobutanesulfonic acid (PFBS)	2.00	2.06	J	ng/L		103	50 - 150
Perfluoroheptanoic acid (PFHpA)	2.00	1.89	J	ng/L		94	50 - 150
Perfluorononanoic acid (PFNA)	2.00	2.17	J	ng/L		108	50 - 150
Perfluorotetradecanoic acid (PFTA)	2.00	1.59	J	ng/L		79	50 - 150
Perfluorotridecanoic acid (PFTTrDA)	2.00	2.07	J	ng/L		103	50 - 150
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid(9Cl-PF3ONS)	2.00	2.06	J	ng/L		103	50 - 150
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11Cl-PF3OUdS)	2.00	1.89	J	ng/L		94	50 - 150
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	2.00	1.55	J	ng/L		77	50 - 150

Surrogate	MRL %Recovery	MRL Qualifier	Limits
d5-NEtFOSAA	85		70 - 130
13C2 PFHxA	93		70 - 130
13C2 PFDA	105		70 - 130
13C3-GenX	73		70 - 130

Lab Sample ID: 380-200977-T-1-A MS
Matrix: Water
Analysis Batch: 211878

Client Sample ID: Matrix Spike
Prep Type: Total/NA
Prep Batch: 211717

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	Limits
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX)	<2.0		25.1	22.6		ng/L		90	70 - 130
Perfluorooctanesulfonic acid (PFOS)	<2.0		25.1	25.3		ng/L		97	70 - 130
Perfluoroundecanoic acid (PFUnA)	<2.0		25.1	25.3		ng/L		101	70 - 130
N-methylperfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0		25.1	24.7		ng/L		98	70 - 130

Eurofins Pomona

QC Association Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

LCMS

Prep Batch: 211527

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-201236-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	533	
380-201236-2	FB MOANALUA WELLS (331-223-TP202)	Total/NA	Water	533	
MBL 380-211527/20-A	Method Blank	Total/NA	Water	533	
LCS 380-211527/22-A	Lab Control Sample	Total/NA	Water	533	
MRL 380-211527/21-A	Lab Control Sample	Total/NA	Water	533	
380-201381-B-1-A MS	Matrix Spike	Total/NA	Water	533	
380-201381-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	

Analysis Batch: 211576

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-201236-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	533	211527
380-201236-2	FB MOANALUA WELLS (331-223-TP202)	Total/NA	Water	533	211527
MBL 380-211527/20-A	Method Blank	Total/NA	Water	533	211527
LCS 380-211527/22-A	Lab Control Sample	Total/NA	Water	533	211527
MRL 380-211527/21-A	Lab Control Sample	Total/NA	Water	533	211527
380-201381-B-1-A MS	Matrix Spike	Total/NA	Water	533	211527
380-201381-C-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	533	211527

Prep Batch: 211717

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-201236-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	537.1 DW	
380-201236-2	FB MOANALUA WELLS (331-223-TP202)	Total/NA	Water	537.1 DW	
MBL 380-211717/19-A	Method Blank	Total/NA	Water	537.1 DW	
LCS 380-211717/21-A	Lab Control Sample	Total/NA	Water	537.1 DW	
MRL 380-211717/20-A	Lab Control Sample	Total/NA	Water	537.1 DW	
380-200977-T-1-A MS	Matrix Spike	Total/NA	Water	537.1 DW	
380-200977-U-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	537.1 DW	

Analysis Batch: 211878

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
380-201236-1	MOANALUA WELLS (331-223-TP202)	Total/NA	Drinking Water	EPA 537.1 V2	211717
380-201236-2	FB MOANALUA WELLS (331-223-TP202)	Total/NA	Water	EPA 537.1 V2	211717
MBL 380-211717/19-A	Method Blank	Total/NA	Water	EPA 537.1 V2	211717
LCS 380-211717/21-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	211717
MRL 380-211717/20-A	Lab Control Sample	Total/NA	Water	EPA 537.1 V2	211717
380-200977-T-1-A MS	Matrix Spike	Total/NA	Water	EPA 537.1 V2	211717
380-200977-U-1-A MSD	Matrix Spike Duplicate	Total/NA	Water	EPA 537.1 V2	211717

Lab Chronicle

Client: City & County of Honolulu
 Project/Site: RED-HILL

Job ID: 380-201236-1
 SDG: PFAS: Moanalua Wells

Client Sample ID: MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-1

Date Collected: 03/02/26 10:16

Matrix: Drinking Water

Date Received: 03/04/26 10:01

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			211527	XTD8	EA POM	03/07/26 05:29
Total/NA	Analysis	533		1	211576	SZ9R	EA POM	03/08/26 17:31
Total/NA	Prep	537.1 DW			211717	G9MN	EA POM	03/09/26 01:16
Total/NA	Analysis	EPA 537.1 V2		1	211878	M7ML	EA POM	03/10/26 01:00

Client Sample ID: FB MOANALUA WELLS (331-223-TP202)

Lab Sample ID: 380-201236-2

Date Collected: 03/02/26 10:16

Matrix: Water

Date Received: 03/04/26 10:01

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	533			211527	XTD8	EA POM	03/07/26 05:29
Total/NA	Analysis	533		1	211576	SZ9R	EA POM	03/08/26 17:41
Total/NA	Prep	537.1 DW			211717	G9MN	EA POM	03/09/26 01:16
Total/NA	Analysis	EPA 537.1 V2		1	211878	M7ML	EA POM	03/10/26 01:10

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

Accreditation/Certification Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Laboratory: Eurofins Pomona

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Hawaii	State	CA00006	01-31-26 *

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Method Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Method	Method Description	Protocol	Laboratory
533	Perfluorinated and Polyfluorinated Alkyl Substances in Drinking Water	EPA	EA POM
EPA 537.1 V2	EPA 537.1 Ver. 2.0 March 2020	EPA	EA POM
533	Extraction of Perfluorinated and Polyfluorinated Alkyl Acids	EPA	EA POM
537.1 DW	Extraction of Perfluorinated Alkyl Acids	EPA	EA POM

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA POM = Eurofins Pomona, 941 Corporate Center Drive, Pomona, CA 91768-2642, TEL (626)386-1100

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Sample Summary

Client: City & County of Honolulu
Project/Site: RED-HILL

Job ID: 380-201236-1
SDG: PFAS: Moanalua Wells

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	Sample Origin
380-201236-1	MOANALUA WELLS (331-223-TP202)	Drinking Water	03/02/26 10:16	03/04/26 10:01	Hawaii
380-201236-2	FB MOANALUA WELLS (331-223-TP202)	Water	03/02/26 10:16	03/04/26 10:01	Hawaii

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17

Monrovia, CA (Suite 100)
 750 Royal Oaks Drive Suite 100
 Monrovia, CA 91016
 Phone (626) 386-1100

Chain of Custody Record



Client Information		Sampler: bailey	Lab PM: Lopez, Maria	Carrier Tracking No(s):	COC No:
Client Contact: kirk Iwamoto		Phone: +1 808 748 5840	E-Mail: Maria.Lopez@et.eurofinsus.com	State of Origin:	Page: Page 1 of 1
Company: City & County of Honolulu		PWSID:		Job #:	
Address: 630 South Beretania Street, Chemistry Lab		Due Date Requested:		Analysis Requested	
City: Honolulu		TAT Requested (days):		Field Filtered Sample (Yes or No)	
State, Zip: HI, 96843		Compliance Project: Δ No		Perform MS/MSD (Yes or No)	
Phone: 808-748-5840 (tel)		PO #: C20525101 exp 05312023		SUBCONTRACT - 826 PAH Physic LL (EAL) + TICs	
Email: kiwamoto@hbws.org		WO #: 38001111		8018B_GRO_LL - (MOD) GRO	
Project Name: RED-HILL/HBWS sites Event Desc: RUSH Weekly Red Hill		SSOW#: 38001111		818B_DRO_LL_C8 - HNL Ranges: C10-C24/C24-C38/C8-C18	
Site:		Sample Date: 2-Mar-2026		526.2_PREC - (MOD) 826plus PLUS TICs	
Sample Identification		Sample Time: 1016		537.1_DW_PREC - 637.1 Full List	
Moanalua Wells		Sample Type (C=Comp, G=grab): G		533 - All Analytes	
		Preservation Code: Water		Total Number of Containers	
FB Moanalua Wells		2-Mar-2026		Special Instructions/Note: chlorinated	
		1016		380-201236 COC	
				QR Code	
				380-201236 COC	
Possible Hazard Identification		Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		Months	
<input type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown <input type="checkbox"/> Radiological		<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For			
Deliverable Requested: I, II, III, IV, Other (specify)		Special Instructions/QC Requirements:			
Empty Kit Relinquished by		Date:		Time:	
Relinquished by		Date/Time: 03/11/2026 1400		Date/Time: 3/12/26 1001	
Custody Seals Intact: Δ Yes Δ No		Custody Seal No.:		Cooler Temperature(s) °C and Other Remarks: (31A) 1.8 + 1.2 = 2.0 get to 20	



Login Sample Receipt Checklist

Client: City & County of Honolulu

Job Number: 380-201236-1
SDG Number: PFAS: Moanalua Wells

Login Number: 201236
List Number: 1
Creator: Ngo, Theodore

List Source: Eurofins Pomona

Question	Answer	Comment
The coolers custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
Samples were received on ice.	True	
Cooler(s) Temperature is acceptable.	True	
Cooler(s) Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and is legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
CIO4 headspace requirement met (>50% for CA, >30% for other states).	N/A	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	

